



**NATIONAL WATER & SEWERAGE CORPORATION**  
**WATER QUALITY MANAGEMENT DEPARTMENT**  
**KIGUMBA WATER AREA**

**Report date:** 30<sup>th</sup> June-2016

**Table:** Water quality for Selected zones in Kigumba during the week of 24th June 2016

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Kigarara	Police	Parents S.S	Kabukye PSP	
CODE		N150	N151	N152	N153	N154	N155	
pH	....	7.2	7.3	7.1	7.2	7.0	7.1	5.5 – 8.5
Turbidity	NTU	0.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	2	1	0	0	0	5	≤15
Iron	Mg/l	0.30	0.05	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/A	NR	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	NA	0.50	0.30	0.20	0.30	0.40	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	3	0	0	0	0	0	0