

KIGUMBA AREA**Report date:** 15th September -2015**Table:** Water quality for Selected zones in Kigumba during the week of 11th September 2015

Parameter				Monitoring points			National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply			
				Kigumba Parents	Kigumba H/C	Kigumba Total	
Codes		N4347	N4348	N4349	N4350	N4351	
pH	8.5	8.8	8.3	8.7	8.3	5.5 – 8.5
Turbidity	NTU	30.00	0.34	0.28	0.57	0.36	≤5.00
Colour	PtCo.	3800	4	1	1	2	≤15
Iron	Mg/l	0.007	0.003	0.001	0.000	0.004	≤0.300
Residue Aluminium	Mg/l	N/A	0.01	0.00	0.00	0.02	≤0.20
Free chlorine	Mg/L	N/A	0.65	0.30	0.40	0.35	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	2	0	0	0	0	0

N/A – Not applicable