

KIRYANDONGO AREA**Report date:** 13th January-2016**Table:** Water quality for Selected zones in Kiryandongo during the week of 7th January-2016.

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Police	Water in Supply				
					Town council	Piblo	Hospita l	Kibanda S.S	
pH	7.2	7.0	7.1	7.2	7.2	7.3	7.2	5.5 – 8.5
Turbidity	NTU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	7	1	1	1	0	0	1	≤15
Iron	Mg/L	0.387	0.124	N/A	N/A	N/A	N/A	N/A	≤0.300
Residue Aluminium	Mg/L	NA	N/A	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	0.50	0.30	0.30	0.30	0.20	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	0	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required