

KIRYANDONGO AREA**Report date:** 15th September -2015**Table:** Water quality for Selected points in Kiryandongo during the week of 11th September 2015

Parameter				Monitoring points		National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply	
				Nyakadoli	Kiryadongo Oil Energy	
Codes		N4344	N4345	N4346	N4347	
pH	8.9	8.0	7.8	8.2	5.5 – 8.5
Turbidity	NTU	18	0.65	0.31	0.74	≤5.00
Colour	PtCo.	187	6	1	0	≤15
Iron	Mg/l	0.56	0.12	0.09	0.10	≤0.30
Residue Aluminium	Mg/l	N/A	0.01	0.09	0.01	≤0.20
Free chlorine	mg/L	N/A	0.50	0.40	0.20	0.20 – 0.50
Faecal - Coliform	CFU/100 mL	0	0	0	0	0

N/A – Not applicable