



# NATIONAL WATER & SEWERAGE CORPORATION

## WATER QUALITY MANAGEMENT DEPARTMENT

### KISORO AREA

Report date: 25<sup>th</sup> Jan 2016

**Table:** Water quality for Selected points in **KISORO** during the week starting 20<sup>th</sup> Jan 2016

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Kisoro Reserv oirs	Kisoro Town Center	Kabale Road	Busamba	Bunag ana	
Codes		N071	N072	N073	N074	N075	N076	N077	
pH	....	7.3	7.3	7.4	7.3	7.3	7.5	7.5	5.5 – 8.5
Turbidity	NTU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	0	0	0	0	0	0	0	≤15
Iron	Mg/L	N/D	N/D	N/R	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/L	N/R	N/R	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	N/A	0.35	0.30	0.20	0.30	0.25	0.21	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	5	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required