



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

KISORO AREA

Report date: 29th Aug 2016

Table: Water quality for Selected zones in **KISORO AREA** during the week ending 25th Aug **2016**

Parameter				Monitoring points			National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply			
				Kisoro Reservoir	Town Center	Busamba	
Codes		N314	N315	N316	N317	N318	
pH	7.2	7.3	7.3	7.4	7.6	5.5 – 8.5
Turbidity	NTU	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	0.00	0.00	0.00	0.00	0.00	≤15
Iron:Total	Mg/l	N/A	N/A	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/A	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	NA	0.34	0.34	0.23	0.20	0.20 – 0.50
Faecal – Coliform	CFU/ 100 mL	2	0	0	0	0	0