



NATIONAL WATER & SEWERAGE CORPORATION

WATER QUALITY MANAGEMENT DEPARTMENT

KISORO AREA

Report date: 3rd November 2016

Table: Water quality for Selected zones in **Kisoro** during the week of 27th October, 2016

Parameter				Monitoring points			National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply			
				Kisoro Reservoir	Town Center	Bunagana	
Codes		N382	N383	N384	N385	N386	
pH	7.2	7.3	7.3	7.3	7.4	5.5 – 8.5
Turbidity	NTU	0.00	0.00	0.00	0.00	0.00	≤5.00
Free chlorine	mg/L	NA	0.24	0.24	0.22	0.22	0.20 – 0.50
Faecal –Coliform	CFU/ 100 mL	0	0	0	0	0	0