



**NATIONAL WATER & SEWERAGE CORPORATION  
WATER QUALITY MANAGEMENT DEPARTMENT**

**KISORO**

**Report date:** 12<sup>th</sup> Oct 2016

**Table:** Water quality for Selected zones in **KISORO AREA** during the week of 6<sup>th</sup> Oct2016

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Kisoro Reservoir	Nturo	Ndimiro	Nyakabande	
Codes		N358	N359	N360	N349	N351	N352	
pH	....	7.2	7.2	7.2	7.6	7.7	7.3	5.5 – 8.5
Turbidity	NTU	0.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	2	0	0	0	1	0	≤15
Free chlorine	mg/L	NA	0.25	0.25	0.24	0.23	0.22	0.20 – 0.50
Faecal – Coliform	CFU/ 100 mL	0	0	0	0	-	-	0