



# NATIONAL WATER & SEWERAGE CORPORATION

## WATER QUALITY MANAGEMENT DEPARTMENT

### KISORO AREA

**Report date:** 21<sup>st</sup> January-2016

**Table:** Water quality for Selected zones in KISORO during the week of 11<sup>th</sup> January. 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply				
				Kisoro Reservoirs	Nyakabande	Kisoro Town Center	Muramba	
Codes		N064	N065	N066	N067	N069	N070	
pH	....	7.2	7.3	7.3	7.5	7.4	7.5	5.5 – 8.5
Turbidity	NTU	0.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	0	0	0	0	0	0	≤15
Iron	Mg/L	N/D	N/D	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/L	N/R	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	N/A	0.70	0.70	0.30	0.44	0.28	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required