



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

KISORO AREA

Report date: 2nd March 2016

Table: Water quality for Selected zones in **KISORO** during the week of 25th February 2016

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Kisoro Reservoir	Nyakabande	Kisoro Town Center	Bunagana	Mutolere	
Codes		N025	N026	N027	N028	N029	N030	N031	
pH	7.7	7.4	7.4	7.4	7.4	7.5	7.6	5.5 – 8.5
Turbidity	NTU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	43	11	8	9	7	8	10	≤15
Iron	Mg/l	N/R	N/R	N/R	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/R	N/R	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/R	0.60	0.60	0.27	0.39	0.29	N/R	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	-	0	0	0	0	0	-	0