

KISORO AREA**Report date:** 8th December -2015**Table:** Water quality for Selected points in **KISORO** during the week starting 3rd December 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Kisoro Reserv oir	Kisoro Center	Bunagan a	Kamonyi	Chahi	
Codes		N050	N051	N052	N053	N054	N055	N056	
pH	7.2	7.5	7.5	7.5	7.5	7.5	7.5	5.5 – 8.5
Turbidity	NTU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	0	0	0	0	0	0	0	≤15
Iron	Mg/l	N/D	N/D	N/R	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/l	N/R	N/R	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/A	0.39	0.39	0.34	0.23	0.30	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	0	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required