

KISORO AREA**Report date:** 20th October -2015**Table:** Water quality for Selected points in KISORO during the week starting 12th October 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in supply					
				Kisoro Res	Kisoro Center	Kisoro-Kabale Road	Bunagana	Chuhu Road	
Codes		N022	N023	N024	N025	N026	N027	N028	
pH	7.1	7.4	7.4	7.4	7.3	7.3	7.4	5.5 – 8.5
Turbidity	NTU	0	0	0	0	0	0	0	≤5.00
Colour	PtCo.	0	0	0	0	0	0	0	≤15
Iron	Mg/l	N/D	N/D	N/R	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/l	N/R	N/R	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/A	0.57	0.57	0.35	0.40	0.26	0.40	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	-	0	0	0	0	0	0	0

NR: Not required