

## KISORO AREA

**Report date:** 24<sup>th</sup> December -2015

**Table:** Water quality for Selected points in **Kisoro** during the week of 17<sup>th</sup> December 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Kisoro Reservoirs	Kisoro Town Center	Kabale Road	Busamb a	Bunagan a	
Codes		N057	N058	N059	N060	N061	N062	N063	
pH	....	7.2	7.4	7.4	7.5	7.4	7.6	7.6	5.5 – 8.5
Turbidity	NTU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	0	0	0	0	0	0	0	≤15
Iron	Mg/L	N/D	N/D	N/R	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/L	N/R	N/R	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	N/A	0.41	0.41	0.10	0.31	0.20	0.32	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	1	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required