

KISORO AREA

Report date: 30th December - 2015

Table: Water quality for Selected points in Kisoro during the week of 24th December 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Kisoro Reservoirs	Kisoro Town Center	Kabale Road	Busamb a	Bunagana	
CODE		N064	N065	N066	N067	N068	N069	N070	
pH	7.2	7.4	7.4	7.5	7.4	7.6	7.6	5.5 – 8.5
Turbidity	NTU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	0	0	0	0	0	0	0	≤15
Iron	Mg/l	N/D	N/D	N/R	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/l	N/R	N/R	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/A	0.40	0.41	0.20	0.21	0.20	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	0	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required