

**KISORO AREA****Report date:** 30<sup>TH</sup> November -2015**Table:** Water quality for Selected points in **KISORO** during the week of 26<sup>th</sup> November 2015

Parameter				Monitoring points					National Standard For potable water quality
	Unit	Raw water	Final water	Water in Supply					
				Kisoro Reserv oir	Kisoro Center	Bunagan a	Kamonyi	Busam ba	
Codes		N043	N044	N045	N046	N047	N048	N049	
pH	NA	7.2	7.4	7.4	7.4	7.5	7.6	7.5	5.5 – 8.5
Turbidity	NTU	0.00	0.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	0	0	0	0	0	0	0	≤15
Iron	Mg/l	N/R	N/R	N/R	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/l	N/R	N/R	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/A	0.60	0.60	0.30	0.32	0.27	0.30	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	0	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required