



**NATIONAL WATER & SEWERAGE CORPORATION  
WATER QUALITY MANAGEMENT DEPARTMENT**

**KYOTERA AREA**

**Report date:** 10<sup>th</sup> October 2016

**Table:** Water quality for Selected zones in **Kyotera** Area during the week ending 6<sup>th</sup> October, 2016

Parameter	Unit	Raw water	Final water	Monitoring points			National Standard For potable water quality (Water in Supply)
				Kyakonda	Kabaseke	Kasambya	
<b>Codes</b>		<b>4430</b>	<b>4431</b>	<b>4432</b>	<b>4433</b>	<b>4434</b>	
pH	....	6.7	6.5	6.6	6.8	6.5	<b>5.5 – 8.5</b>
Turbidity	NTU	5.15	0.20	0.10	0.18	0.16	<b>≤5.00</b>
Colour	PtCo.	1	0	0	0	0	<b>≤15</b>
Iron	Mg/l	1.02	0.18	N/R	N/R	N/R	<b>≤0.300</b>
Free chlorine	mg/L	NA	0.25	0.20	0.20	0.25	<b>0.20 – 0.50</b>
Faecal – Coliform	CFU/ 100 mL	N/A	0	0	0	0	<b>0</b>

N/A-Not applicable, N/R-Not required.