



NATIONAL WATER & SEWERAGE CORPORATION

WATER QUALITY MANAGEMENT DEPARTMENT

LIRA AREA

Report date: 23rd June 2016

Table: Water quality for Selected zones in Lira during the week of 16th June, 2016..

Parameter	Unit	Monitoring points						National Standards for potable water quality (water in supply)
		Waterworks		Water in Supply				
		Raw water	Final water	Ojwina Division	Central Division	Adyeda Division	Railways Division	
Codes		N145	N146	N147	N148	N149	N150	
pH	...	6.9	6.4	6.5	6.5	6.4	6.7	5.5-8.5
Turbidity	NTU	4.71	2.01	2.12	2.21	2.31	2.23	≤5
Colour	PtCo.	65	10	11	11	12	11	≤15
Aluminium Residue	mg/L	N/A	0.11	N/R	N/R	N/R	N/R	≤0.200
Iron	mg/L	0.088	0.012	0.022	0.021	0.026	0.023	≤0.300
Free chlorine	mg/L	N/A	0.85	0.25	0.40	0.21	0.25	0.20 – 0.50
Faecal -Coliform	CFU/ 100 mL	10	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required