

**LIRA AREA****Report date:** 27<sup>th</sup> July -2015**Table:** Water quality for Selected zones in Lira during the week of 20<sup>th</sup> July 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Ojwina Divisio n	Adyel Division	Railways Division	Central Division	
pH	....	8.25	7.8	7.38	7.67	7.55	7.4	5.5 – 8.5
Turbidity	NTU	16	3.00	2.00	3.00	2.00	2.00	≤5.00
Colour	PtCo.	50	10	9	10	11	10	≤15
Free chlorine	mg/L	NA	1.18	0.30	0.30	0.25	0.26	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	12	0	0	0	0	0	0