

LIRA AREA**Report date:** 22nd June 2015**Table:** Average water quality for different Divisions in Lira during the week of 15th June 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply				
				Ojwina Division	Central Division	Adyel division	Railways division	
pH	8.00	7.60	7.60	7.50	7.60	7.70	5.5 – 8.5
Turbidity	NTU	14	2	3	2	2	3	≤5
Colour	PtCo.	65	08	11	10	10	11	≤15
Free chlorine	mg/L	N/A	1.18	0.30	0.25	0.30	0.25	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	18	0	0	0	0	0	0