

**LIRA AREA****Report date:** 26<sup>th</sup> September -2015**Table:** Water quality for Selected points in Lira during the week of 25<sup>th</sup> September, 2015

Parameter	Monitoring points							National Standards for potable water quality
	Unit	Raw water	Treated Water	Water in Supply				
				Ojwina Division	Adyel Division	Railways Division	Central Division	
CODES		N001	N 004	N042	N032	N037	N021	
pH	...	8.27	7.85	7.73	7.8	7.8	7.89	5.5 – 8.5
Turbidity	NTU	>10	<5	<5	< 5	<5	3	≤5.00
Colour	PTU	65	10	9	10	10	9	≤15
Iron	mg/L	0.09	0.07	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	mg/L	N/R	0.17	N/R	N/R	N/R	N/R	≤0.20
Free Chlorine	mg/L	NA	1	0.25	0.22	0.25	0.22	0.20 – 0.50
Faecal - Coliforms	CFU/ 100ml	20	0	0	0	0	0	0

N/R-Not Required