

LUWEERO AREA**Report date:** 27th July -2015**Table:** Water quality for selected points in Luweero during the week of 20th July 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water	Water in Supply				
				Kinene	Light of life	Destiny High school	Kalongo PSP	
pH	...	6.00	6.8	6.6	6.6	6.6	6.8	6.5 – 8.5
Turbidity	NTU	0.13	0.15	0.27	0.51	0.20	0.26	≤5.00
Colour	PTU	0	0	0	0	0	0	≤15
Free chlorine	mg/l	N/A	0.30	0.30	0.30	0.30	0.20	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	0	0	0	0	0	0	0