

LUWERO AREA**Report date:** 29th June 2015**Table:** Water quality for selected points in Luwero during the week of 22nd June 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Kasana Hosp	Kalongo PSP	Kasana	Kinene	Destiny	
pH	...	6.08	5.92	6.52	6.52	6.62	6.65	6.67	5.5 – 8.5
Turbidity	NTU	1.00	0.00	0.00	1.00	1.00	1.00	0.00	≤5
Colour	PtCo.	2	0	2	2	2	2	2	≤15
Free chlorine	mg/L	N/A	0.30	0.20	0.20	0.21	0.24	0.20	0.20 – 0.50
Faecal -Coliform	CFU/ 100 mL	0	0	0	0	0	0	0	0