

LUWERO AREA

Report date: 13th July 2015

Table: Water quality for selected points in Luwero during the week of 6th July 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Kinene	Light of life	Destiny	Kalong o	Kasan a	
pH	...	5.95	6.75	6.62	6.55	6.63	6.76	6.55	5.5 – 8.5
Turbidity	NTU	0.127	0.142	0.266	0.505	0.199	0.261	0.238	≤5
Colour	PtCo.	0	0	0	0	0	0	0	≤15
Free chlorine	mg/L	NA	0.5	0.3	0.2	0.3	0.2	0.3	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	0	0	0	0	0	0	0	0