

LYANTONDE AREA**Report date:** 20th October -2015**Table:** Water quality for Selected zones in Lyantonde during the week starting 12th October 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply				
				Town Reservoir	Kagate	Hospital (North)	Mukokoma	
Codes		N043	N044	N045	N046	N047	N048	
pH	7.1	7.4	7.8	7.6	7.6	7.6	5.5 – 8.5
Turbidity	NTU	31.10	0.25	2.00	1.00	0	2.00	≤5.00
Colour	PtCo .	319	4	4	1	2	11	≤15
Iron	Mg/l	0.700	0.040	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/R	0.00	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/R	1.56	0.30	0.30	0.20	0.20	0.20 – 0.50
Faecal Coliform	CFU/ 100 mL	N/R	0	0	0	0	0	0

NR: not required