



**NATIONAL WATER & SEWERAGE CORPORATION  
WATER QUALITY MANAGEMENT DEPARTMENT**

**MASAKA AREA**

**Report date:** 14<sup>th</sup> July -2016

**Table:** Water quality for Selected points in Masaka during the week starting 11<sup>th</sup> July 2016

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Kyabaku za	Katwe- Buteng o	Nyendo	Kimanya	
CODE		M531	M532	N534	N538	N539	N540	
pH	....	4.9	5.6	6.1	6.2	6.11	6.04	5.5 – 8.5
Turbidity	NTU	28	2.88	2.61	1.19	2.03	2.66	≤5.00
Colour	PtCo.	618	10	14	3	11	15	≤15
Iron	Mg/l	7.23	0.22	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	NR	0.14	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	NA	0.86	0.48	0.23	0.20	0.24	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	300	0	0	0	0	0	0