



**NATIONAL WATER & SEWERAGE CORPORATION**  
**WATER QUALITY MANAGEMENT DEPARTMENT**

**MASAKA AREA**

**Report date:** 23<sup>rd</sup> June-2016

**Table:** Water quality for Selected points in Masaka during the week of 16th June2016

Parameter				Monitoring points				National Standard
	Unit	Raw water	Final water		Water in Supply			For potable water quality  (Water in Supply)
				Kyabakuzaza	Katwe-Butengo	Nyendo	Kimanya	
CODE		M501	M502	M504	M508	M509	M510	
pH	....	6.3	6.2	5.7	6.2	6.3	5.8	5.5 – 8.5
Turbidity	NTU	22.4	3.17	2.78	2.47	2.08	2.37	≤5.00
Colour	PtCo.	469	14	15	13	8	13	≤15
Iron	Mg/l	14.2	0.22	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	NR	0.16	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	NA	0.80	0.52	0.20	0.27	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	488	0	0	0	0	0	0