



**NATIONAL WATER & SEWERAGE CORPORATION  
WATER QUALITY MANAGEMENT DEPARTMENT**

**MASAKA AREA**

**Report date:** 10<sup>th</sup> June-2016

**Table:** Water quality for Selected points in Masaka during the week starting 2<sup>nd</sup> June 2016

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Kyabakuz a	Katwe- Butengo	Nyendo	Kimanya	
CODE		M481	M482	M484	M488	M489	M490	
pH	....	6.3	6.0	6.3	6.3	6.3	6.4	5.5 – 8.5
Turbidity	NTU	18	2.66	2.57	2.09	2.28	2.27	≤5.00
Colour	PtCo.	362	15	12	9	13	11	≤15
Iron	Mg/l	17.00	0.25	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	NR	0.15	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	NA	0.60	0.41	0.26	0.22	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	416	0	0	0	0	0	0