



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

MASAKA AREA

Report date: 15th September-2016

Table: Water quality for Selected points in Masaka during the week of 8th September 2016

Parameter	Unit	Raw water	Final water	Monitoring points				National Standard For potable water quality (Water in Supply)
				Katwe	Nyendo	Kimanyi	kyabak uza	
CODE		M621	M622	M628	M629	M630	M631	
pH	6.1	6.1	6.3	6.3	6.3	6.2	5.5 – 8.5
Turbidity	NTU	16.20	2.16	2.16	2.11	2.16	2.20	≤5.00
Colour	PtCo.	508	12	9	8	9	10	≤15
Iron	Mg/l	6.810	0.187	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	NR	0.161	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	NA	1.14	0.22	0.21	0.23	0.21	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	80	0	0	0	0	0	0