



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

MASAKA AREA

Report date: 6th April 2016

Table: Water quality for Selected zones in **Entebbe** during the week of 30th March 2016

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Kitovu	Katwe – Butego	Nyendo	Kimanya	Kitovu	
Codes		M401	M403	M406	M408	M409	M410	M401	
pH	5.9	6.1	6.4	6.2	6.2	6.5	5.9	5.5 – 8.5
Turbidity	NTU	16.40	2.67	2.84	0.77	1.78	3.17	16.40	≤5.00
Colour	PtCo.	314	11	14	2	9	13	314	≤15
Iron	Mg/l	16.750	0.240	0.390	0.280	0.320	0.270	16.750	≤0.300
Residue Aluminium	Mg/l	N/R	N/R	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	N/A	1.07	0.39	0.28	0.32	0.27	0.24	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	202	0	0	0	0	0	202	0

NA: Not applicable, N/R: Not Required