

**MASAKA AREA****Report date:** 2<sup>nd</sup> November -2015**Table:** Water quality for Selected points in Masaka during the week starting 26<sup>th</sup> October 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Kitovu	Katwe-Buteng o	Nyendo	Kimanya	
CODE		M181	M182	N186	N188	N189	N190	
pH	....	5.9	6.24	6.2	6.2	6.3	6.3	5.5 – 8.5
Turbidity	NTU	13.99	1.73	3.31	1.93	2.28	1.78	≤5.00
Colour	PtCo.	260	5	14	10	13	9	≤15
Iron	Mg/l	17.1	0.20	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/l	NA	0.15	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	Mg/L	NA	0.69	0.24	0.22	0.21	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	44	0	0	0	0	0	0

NA: Not applicable, N/R: Not Reported