

## MASAKA AREA

**Report date:** 20<sup>th</sup> October -2015

**Table:** Water quality for Selected points in Masaka during the week starting 12<sup>th</sup> October 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Kitovu	Katwe	Nyendo	Kimanya	
CODE		N161	N162	N163	N164	N165	N166	
pH	....	6.2	6.2	6.2	6.2	6.2	6.3	5.5 – 8.5
Turbidity	NTU	14.70	1.61	2.59	2.28	1.06	1.33	≤5.00
Colour	PtCo.	318	5	11	7	3	3	≤15
Iron	Mg/l	7.62	0.27	NR	NR	NR	NR	≤0.300
Residue Aluminium	Mg/l	NR	0.15	NR	NR	NR	NR	≤0.20
Free chlorine	mg/L	NA	0.72	0.20	0.24	0.18	0.22	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	38	0	0	0	0	0	0

NR: Not required