

MASAKA AREA**Report date:** 22nd June 2015**Table:** Water quality for selected points in Masaka during the week of 15th June 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Kitovu	Zebra Hotel	Kizungu	Kyaba kuza police	Elgin Road	
pH	...	5.60	6.00	6.00	5.50	6.00	6.5	60	5.5 – 8.5
Turbidity	NTU	8.2	0.7	0.6	0.4	0.6	0.2	2.9	≤5
Colour	PtCo.	250	2	8	0	0	13	9	≤15
Free chlorine	mg/L	N/A	0.99	0.21	0.17	0.22	0.23	0.11	0.20 – 0.50
Faecal -Coliform	CFU/ 100 mL	50	0	0	0	0	0	0	0