

**MASAKA AREA****Report date:** 29<sup>th</sup> June 2015**Table:** Water quality for different zones in Masaka during the week of 22<sup>nd</sup> June 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply				
				Kyabakuza	Kitovu	Kako	Central- taxi park area	
pH	...	5.0	7.1	6.5	6.0	6.0	6.5	5.5 – 8.5
Turbidity	NTU	10.83	0.93	0.89	0.18	1.16	0.94	≤5
Colour	PtCo.	237	3	11	3	15	12	≤15
Free chlorine	mg/L	N/A	1.30	0.31	0.22	0.19	0.19	0.20 – 0.50
Faecal -Coliform	CFU/ 100 mL	30	0	0	0	0	0	0