

**MASAKA AREA****Report date:** 30<sup>th</sup> December - 2015**Table:** Water quality for Selected zones in Masaka during the week of 24<sup>th</sup> December 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Katwe Butego	Nyendo	Kiman ya	Kitovu	Boma	
CODE		N261	N262	N268	N269	N279	N265	N266	
pH	....	7.4	7.0	6.7	6.8	6.6	6.4	6.4	5.5 – 8.5
Turbidity	NTU	14.62	1.22	0.88	1.34	1.68	1.04	1.58	≤5.00
Colour	PtCo.	483	0	0	0	0	0	0	≤15
Iron	Mg/l	0.74	0	N/A	N/A	N/A	N/A	N/A	≤0.30
Residue Aluminium	Mg/l	NA	0.06	N/A	N/A	N/A	N/A	N/A	≤0.20
Free chlorine	Mg/L	N/A	0.63	0.20	0.20	0.20	0.27	0.21	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	90	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required