

MASAKA AREA**Report date:** 7th October -2015**Table:** Water quality for Selected points in Masaka during the week of 2nd October 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Kitovu	Katwe	Nyendo	Kimanya	
CODE		N141	N142	N146	N148	N149	N150	
pH	6.0	6.5	6.3	6.2	6.7	6.4	5.5 – 8.5
Turbidity	NTU	117.55	1.46	3.88	2.66	2.90	1.79	≤5.00
Colour	PtCo.	903	6	14	11	9	3	≤15
Iron	Mg/l	10.040	0.280	NR	NR	NR	NR	≤0.300
Residue Aluminium	Mg/l	NR	0.13	NR	NR	NR	NR	≤0.20
Free chlorine	mg/L	NA	0.77	0.23	0.24	0.20	0.2	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	40	0	0	0	0	0	0