

## MASAKA AREA

**Report date:** 13<sup>th</sup> June 2015

**Table:** Water quality for selected points in Masaka during the week of 6<sup>th</sup> July 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply				
				Kyabakuza	Kitovu	Katwe-Butego	Nyendo	
pH	---	4.6	6.5	7.0	6.0	7	7	5.5 – 8.5
Turbidity	NTU	9.6	0.49	0.97	1.03	0.28	0.77	≤5
Colour	PtCo.	339	2	10	9	0	8	≤15
Free chlorine	mg/L		1.00	0.48	0.38	0.24	0.2	0.20 – 0.50
Faecal -Coliform	CFU/100 mL	110	0	0	0	0	0	0