



NATIONAL WATER & SEWERAGE CORPORATION

WATER QUALITY MANAGEMENT DEPARTMENT

MASINDI AREA

Report date: 3rd November 2016

Table: Water quality for Selected zones in **Masindi** during the week of 27th October, 2016

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Elevated Reservoir	Nyangaya	Karujubu	Masindi Town Center	
Codes		-	-	-	-	-	-	
pH	6.8	6.5	6.9	6.7	6.7	6.8	5.5 – 8.5
Turbidity	NTU	2.10	0.00	0.00	0.00	0.00	0.00	≤5.00
Iron	Mg/l	7.900	0.300	N/R	N/R	N/R	N/R	≤0.300
Free chlorine	mg/L	NA	1.30	0.30	0.70	0.20	0.30	0.20 – 0.50
Faecal –Coliform	CFU/ 100 mL	-	0	0	0	0	0	0