



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

MASINDI AREA

Report date: 29th Aug 2016

Table: Water quality for Selected zones in **MASINDI AREA** during the week ending 25th 2016

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Elevated Reservoir	Nyangay a	Karujub u	Masindi Town Center	
Codes		N026	N027	N028	N029	N030	N031	
pH	6.7	6.4	6.9	6.8	6.9	6.9	5.5 – 8.5
Turbidity	NTU	9.38	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	N/R	N/R	N/R	N/R	N/R	N/R	≤15
Iron	Mg/l	N/A	N/A	N/R	N/R	N/R	N/R	≤0.300
Residue Aluminium	Mg/l	N/A	N/A	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	NA	1.30	0.60	0.20	0.20	0.20	0.20 – 0.50
Faecal – Coliform	CFU/ 100 mL	1	0	0	0	0	0	0