

MASINDI AREA**Report date:** 4th July -2015**Table:** Water quality for Selected points in Masindi during the week of 1st July 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply				
				Kyema Boos-te r	Kamun yong	Kyema T/c	St Jude	Kiswat	
pH	6.8	7.2	7.0	7.0	7.0	7.2	7.1	5.5 – 8.5
Turbidity	NTU	11.75	0.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	116	0	2	1	2	3	0	≤15
Free chlorine	mg/L	N/A	1.3	0.1	0.05	0.08	0.1	0.1	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	2	0	0	0	0	0	0	0