

## MASINDI AREA

**Report date:** 30<sup>th</sup> November -2015

**Table:** Water quality for Selected zones in **MASINDI** during the week of **26<sup>th</sup>** November 2015

Parameter				Monitoring points					National Standard For potable water quality
	Unit	Raw water	Final water	Water in Supply					
				Elevated Reservoir	Nyanga ya	Karujjubu	Masindi Town Center	Kigulya	
Codes		N068	N069	N070	N071	N072	N073	N074	
pH	NA	6.6	6.7	6.8	6.8	6.8	6.7	7.0	5.5 – 8.5
Turbidity	NTU	4.60	0.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo	N/R	N/R	N/R	N/R	N/R	N/R	N/R	≤15
Iron	Mg/l	0.90	0.04	N/R	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/l	N/A	0.18	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/A	1.20	0.30	0.20	0.10	0.20	0.20	0.20 – 0.50
Faecal Coliform	CFU/100 mL	11	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required