

MASINDI AREA

Report date: 2nd November -2015

Table: Water quality for Selected zones in Masindi during the week of 26th October 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Concrete Reservoir	Nyanga ya	Karujjubu	Masindi Town Center	Kigulya	
Codes		N061	N062	N063	N064	N065	N066	N067	
pH	6.7	6.9	7.0	7.1	7.2	7.2	7.0	5.5 – 8.5
Turbidity	NTU	5.70	0.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo	N/R	N/R	N/R	N/R	N/R	N/R	N/R	≤15
Iron	Mg/l	0.90	0.04	N/R	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/l	N/A	0.03	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/A	1.30	0.70	0.20	0.20	0.20	0.20	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	2	0	0	0	0	0	0	0

NR: Not Required, NA: Not Applicable