

MASINDI AREA

Report date: 8th December -2015

Table: Water quality for Selected zones in **MASINDI** during the week starting 3rd December 2015

Parameter				Monitoring points					National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply					
				Elevated Reservoir	Nyanga ya	Karujjubu	Masindi Town Center	Kiguly a	
Codes		N075	N076	N077	N078	N079	N080	N081	
pH	6.7	7.0	6.8	6.8	6.8	6.7	7.0	5.5 – 8.5
Turbidity	NTU	4.60	0.00	0.00	0.00	0.00	0.00	0.00	≤5.00
Colour	PtCo.	N/R	N/R	N/R	N/R	N/R	N/R	N/R	≤15
Iron	Mg/l	0.90	0.03	N/R	N/R	N/R	N/R	N/R	≤0.30
Residue Aluminium	Mg/l	N/A	0.19	N/R	N/R	N/R	N/R	N/R	≤0.20
Free chlorine	mg/L	N/A	1.17	0.30	0.20	0.10	0.20	0.20	0.20 – 0.50
Faecal Coliform	CFU/ 100 mL	7	0	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required