

MASINDI AREA**Report date:** 22nd June 2015**Table:** Water quality for selected points in Masindi during the week of 15th June 2015

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Reservo irs	Water in Supply				
				Kirasa	Army Barracks	Army P/S	Bigando	St. Jude	
pH	7.30	7.00	6.80	7.10	7.10	6.90	7.10	5.5 – 8.5
Turbidity	NTU	12.9	0	0	0	0	0	0	≤5
Colour	PtCo.	107.8	0	0	0	0	0	0	≤15
Free chlorine	mg/L	N/A	1.3	0.2	0.2	0.2	0.2	0.2	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	11	0	0	0	0	0	0	0