



**NATIONAL WATER & SEWERAGE CORPORATION
WATER QUALITY MANAGEMENT DEPARTMENT**

MBALE AREA

Report date: 10th Oct 2016

Table: Water quality for **Manafwa** during the week of 6th Oct 2016

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Treated Water	Water in Supply				
				Busiu	Mmusoto	Bunkoko	Mile 6	
Code		N177	N178	N179	N180	N181	N182	
Ph	...	6.9	7.1	7.1	7.2	7.3	7.4	6.5 – 8.5
Turbidity	NTU	72	1.7	1.3	1.3	1.2	1.2	≤5.00
Colour	PTU	283	0	0	0	0	0	≤15
Iron	mg/l	0.35	0.04	0.03	0.01	0.06	0.02	0.30
Residual Al	mg/l	N/A	0.00	0.00	0.00	0.00	0.00	0.20
Free chlorine	mg/l	N/A	1.3	0.4	0.4	0.4	0.4	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	5500	0	0	0	0	0	0

NA: Not applicable