



NATIONAL WATER & SEWERAGE CORPORATION

WATER QUALITY MANAGEMENT DEPARTMENT

MBALE-BONKOKO WW

Report date: 25th January 2016

Table: Water quality for Selected zones in Mbale during the week starting 18th January-2016.

Parameter	Monitoring points								National Standard For potable water quality (Water in Supply)
	Unit	Nabu yong a Raw water	Nabijo Raw water	Treat ed Water r	Water in Supply				
Code		N132	N133	N134	N135	N136	N137	N138	
pH	...	7.3	7.2	7.1	7.1	7.1	7.2	7.1	6.5 – 8.5
Turbidity	NTU	16.00	21.00	0.23	0.26	0.27	0.22	0.00	≤5.00
Colour	PTU	56	45	0	0	1	1	0	≤15
Iron	Mg/L	0.36	0.32	0.05	N/R	N/R	N/R	N/R	0.300
Residual Al	Mg/L	N/A	N/A	0.10	N/R	N/R	N/R	N/R	0.20
Free chlorine	Mg/L	N/A	N/A	1.40	0.50	0.50	0.24	0.35	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	800	1800	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required