

MBALE-MANAFWA AREA**Report date:** 14th December -2015**Table:** Water quality for Selected points in **Manafwa** during the week of 10th December 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water	Water in Supply				
				Busano	Makayi	Nambumali	Luanda	
Codes		N072	N073	N074	N075	N076	N077	
pH	7.0	7.1	7.1	7.1	7.2	7.0	5.5 – 8.5
Turbidity	NTU	175	8.0	0.82	0.65	0.76	0.88	≤5.00
Colour	PtCo.	890	0	0	0	0	0	≤15
Iron	Mg/L	0.60	0.01	0.02	0.02	0.03	0.04	≤0.30
Residue Aluminium	Mg/L	N/A	0.00	0.00	0.00	0.00	0.00	≤0.20
Free chlorine	Mg/L	N/A	1.5	0.53	0.55	0.51	0.52	0.20 – 0.50
Faecal - Coliform	CFU/ 100 mL	3000	0	0	0	0	0	0

NA: Not applicable, N/R: Not Required