

MBALE AREA**Report date:** 3rd July -2015**Table:** Water quality for selected zones in Mbale during the week of 1st July 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Nabuyong a Raw water	Nabijo Raw water	Treated Water	Water in Supply			
					Industrial Division	Wanale Division	Northern Division	
pH	...	7.26	7.31	6.89	6.77	6.80	6.84	6.5 – 8.5
Turbidity	NTU	45	27	0.90	0.70	3.00	0.80	≤5.00
Colour	PTU	200	88	5	8	11	4	≤15
Free chlorine	mg/l	N/A	N/A	0.94	0.43	0.19	0.30	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	2700	1900	0	0	0	0	0