

MBALE AREA**Report date:** 29th June -2015**Table:** Water quality for different zones in Mbale during the week of 22nd June 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Nabuyonga Raw water	Nabijo Raw water	Treated Water	Water in Supply			
					Industrial Division	Wanale Division	Northern Division	
pH	...	7.19	7.3	7.14	6.89	7.10	6.99	6.5 – 8.5
Turbidity	NTU	58	48	0.8	3	5	0	≤5.00
Colour	PTU	156	99	4	5.8	15	0	≤15
Free chlorine	mg/l	N/A	N/A	0.69	0.24	0.20	0.50	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	2100	2000	0	0	0	0	0