

MBALE AREA**Report Date:** 20th October 2015**Table:** Water Quality for Selected Zones in Mbale during the week starting 12th October 2015

Parameter				Monitoring points				National Standard For potable water quality (Water in Supply)
	Unit	Raw water	Final water		Water in Supply			
				Nabumali	Machai	Lulwanda PS	Susano	
CODE		N012	N013	N014	N015	N016	N017	
pH	...	7.7	7.5	8.0	7.9	7.9	7.9	5.5 – 8.5
Turbidity	NTU	41.30	1.56	0.42	0.49	0.47	0.45	≤5.00
Colour	PtCo.	78	1	2	3	3	4	≤15
Aluminium resd.	mg/L	NA	0.18	NR	NR	NR	NR	0.20
Free chlorine	mg/L	NA	1.69	0.5	0.5	0.5	0.49	0.20 – 0.50
Feacal coliforms	CFU/ 100 mL	NA	2500	0	0	0	0	0

NR: Not required