

MBALE AREA**Report date:** 27th July -2015**Table:** Water quality for selected zones in Mbale during the week of 20th July 2015

Parameter	Monitoring points							National Standard For potable water quality (Water in Supply)
	Unit	Nabuyonga Raw water	Nabijoo Raw water	Treated Water	Water in Supply			
					Industrial Division	Wanale Division	Northern Division	
pH	...	7.28	7.24	6.85	6.87	6.91	6.95	6.5 – 8.5
Turbidity	NTU	38.00	32.00	0.90	2.80	2.90	2.10	≤5.00
Colour	PTU	130	110	2	7	6	4	≤15
Free chlorine	mg/l	N/A	N/A	1.10	0.34	0.30	0.28	0.20 – 0.50
Faecal - Coliforms	CFU/ 100 ml	2100	1800	0	0	0	0	0